

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2509

Dated 27/05/2026

It is certified that an inspection team headed by Er. Chandrabhas

(Name of Officers with designation) from Executive Engineer PHED

inspected the Mahaveer Singh Public School, Vill- Naurahan P.O Gajana

(Name & Address of the school) on 21-05-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2509/Lab Amroha/47 dated 27/05/2026

of UP Jal Nigam Amroha (PHED Lab) certified that the

Mahaveer Singh Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 26/05/2027

Signature with Seal: Er. Chandrabhas

Name: Er. Chandrabhas

Designation: Div. Off. U.P. Jal Nigam (Grameen)

Name & Address of the Office: Amroha

To
Mahaveer Singh Public School
Vill- Naurahan P.O. Gajana, Amroha
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Arvind Kumar

MANAGER
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Distt. Amroha

Shashi
PRINCIPAL
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Near Munavarpur Police Chowki
Distt. Amroha



By E-Mail
E-Mail ID cdupjn_amroha@yahoo.com

कार्यालय

अधिशाली अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण),
इमली वाली मढैया, हुसैनपुर चौराहा / आर०टी०ओ० बाईपास, निकट कन्हैया टायर हाउस,
अमरोहा-244221

पत्रांक 2509/ प्रयोगशाला अमरोहा / 47 दिनांक 24/05/26

सेवा में,

Principal,
Mahaveer Singh Public School,
Vill. Naurahan. P.O. Gajana,
Near Munavvarpur Police Chowki
(Amroha) 244221

विषय- पानी की जांच के संबंध में।

महोदय,

उपरोक्त विषयक आपके पत्रांक 004/26 दिनांक 15.05.2026 के संदर्भ में खण्डीय प्रयोगशाला अमरोहा में कार्यरत श्री ललित कुमार (सैम्पल अस्टिंट) द्वारा दिनांक 21.05.2026 को Mahaveer Singh Public School Vill. Naurahan. P.O. Gajana, Near Munavvarpur Police Chowki Distt. Amroha में उपस्थित होकर लाये गये पेयजल नमूने की जांच खण्डीय प्रयोगशाला में की गयी। जांचोपरान्त जांच रिपोर्ट संलग्न कर प्रेषित है।
संलग्नक:- उपरोक्तानुसार।

भवदीय

Chandrahas
(चन्द्रहास)

अधिशाली अभियन्ता

पृ०सं० एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि:- सहायक अभियन्ता/जू०ई०जी० लैब को सूचनार्थ हेतु प्रेषित।

Arvind Kumar

MANAGER
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Distt. Amroha

अधिशाली अभियन्ता

Lachar
PRINCIPAL
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Near Munavvarpur Police Chowki
Distt. Amroha



DISTRICT LEVEL WATER ANALYSIS LABORATORY
U.P. JAL NIGAM (RURAL), AMROHA
KHAND KARYALAY, ATRASI TO JOYA BYPASS ROAD, AMROHA, UTTAR PRADESH, INDIA
244221

Report No. 26/05/36/29 Date: 27.05.26 Lab Id: Page No. 12

Customer Details

Office Name and Address **Mahaveer Singh Public School Vill. Naurahan, Post. Gajana Near Munavvarpur Police Chowki Distt. Amroha**

Ref Letter No & date 004/26 date 15.05.26

Basic details of sample

District	Amroha	Block	Amroha
Gram Panchayat	Naurahan	Village	Naurahan
Habitation	Naurahan	Location	Mahaveer Singh Public School
Water Source Type	Summersible	Sample No.	AMR/C/26/36
Quantity of Sample	1000 ML	Date of S.C	21/05/2026
S. Receiving Date	21/05/2026	Sample Provide by	Mr. Lalit Kumar
Sample Submit	21/05/2026	Sampling Method Used	IS 17614 (Part 1):2024
Analysis Done By	Chemist		
Analysis Start Date	22/05/2026	Analysis Completion date	22/05/2026
		Result Availability Date	22/05/2026

Environmental Condition

Temperature	25±3°C	Relative Humidity	Up to 50±15
-------------	--------	-------------------	-------------

Technical Data of Analysis

S.N		Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Colour (HU)	05	5	15	IS 3025 P-4:2021
2	pH	7.472	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	TURBIDITY (NTU)	3.13	1.0	5.0	IS 3025 P-10:2023
4	TDS (mg/l)	277.8	500	2000	IS 3025 P-16:2023
5	CHLORIDE (mg/l)	30.00	250	1000	IS 3025 P-32:2019
6	TOTAL ALKALINITY (mg/l)	340.00	200	600	IS 3025 P-23:2023
7	TOTAL HARDNESS(mg/l)	180.00	200	600	IS 3025 P-21:2019
8	Calcium (mg/l)	17.62	75	200	IS 3025 P-40:2019
9	Magnesium (mg/l)	33.17	30	100	IS 3025 P-46:2019
10	Fluoride (mg/l)	0.189	1.0	1.5	Apha23th edition-4500 F- Method C (Electrode method):2023

Note —This Certificate refers only to the particular sample(s) submitted for testing..

1. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
2. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
3. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Arvind Kumar
MANAGER
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Distt. Amroha

[Signature]
Authorized Signatory

.....End Of The Report.....

[Signature]
PRINCIPAL
MAHAVEER SINGH PUBLIC SCHOOL
VIII. Naurahan, P.O. Gajana
Near Munavvarpur Police Chowki
Distt. Amroha



BACTERIOLOGICAL ANALYSIS REPORT
DISTRICT LEVEL WATER ANALYSIS LABORATORY

U.P, JAL NIGAM (RURAL) AMROHA

Address- Khand karyalay, Atrasi to Joya bypass Road Amroha Uttar Pradesh Pin-244221

Report No. 26/05/36/29	Date	27.05.26	Page No.	12
Customer Details				
Office Name and Address	Mahaveer Singh Public School Vill. Naurhan, Post. Gajana Near Munavvarpur Police Chowki Distt. Amroha			
Ref Letter No & date	004/26 date.15.05.26			
Basic details of sample				
District	Amroha	Block	Amroha	
Gram Panchayat	Naurahan	Village	Naurahan	
Habitation	Naurahan	Location	Mahaveer Singh Public School	
Water Source	Sumersible	Sample No.	AMR/B/26/36	
Quantity of Sample	1000 ML	Date of S.C	21/05/2026	
Receiving Date	21/05/2026	Sample Provide by	Mr. Lalit Kumar	
Sample Submit	21/05/2026	Sampling Method Used	IS 17514 (Part 1):2024	
Analysis Done by	Microbiologist			
Analysis Start Date	22/05/2026	Analysis Completion date-	22/05/2026	Result Availability Date- 25/05/2026
Environmental Condition				
Temperature	25±3°C	Relative Humidity	Up to 50±15	

Technical Data of Analysis

S.N	Analysed Parameters (Unit of Measurement)	Unit	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E.COLI	CFU	00	Shall not be detectable in 100 ml Sample		APHA 23 rd Edition : 2017
2	T.COLI	CFU	00	Shall not be detectable in 100 ml Sample		APHA 23 rd Edition : 2017

Note —This Certificate refers only to the particular sample(s) submitted for testing..

1. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
2. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
3. Sample will be stored up to 7 days, (in case of non-perishable items only) from the date of issue of test report unless.

(Signature)

(Microbiologist)
Authorized Signatory

End Of The Report.

(Signature)
MANAGER
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Distt. Amroha

(Signature)
PRINCIPAL
MAHAVEER SINGH PUBLIC SCHOOL
Vill. Naurahan, P.O. Gajana
Near Munavvarpur Police Chowki
Distt. Amroha